



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 / ISO 16484-5 is the responsibility of the BACnet Interest Group Europe e. V. (B.I.G.-EU). BTL is a registered trademark of BACnet International (BI).

BACnet Testing Laboratories Product Listing

This product has been tested at the BACnet Testing Laboratory WSPLab and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the B.I.G.-EU website under "Product Catalogue".

Listing Information

Test Laboratory		Listing Status
WSPLab Dr.-Ing. Harald Bitter Kapuzinerweg 7 D-70374 Stuttgart		Listed Product
Vendor		
SAMSON AG Postfach 10 19 01 60019 Frankfurt a.M. Germany		
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of December 2007	Revision 4 (ISO 16484-5:2007)	April 2008

Product Name	Model Number	Firmware Revision
TROVIS 6610 Automation Station	Model 6610-0000	SAMSON BACstack 1.6

Product Name	Link to PICS
TROVIS 6610 Automation Station	see "Product Catalogue" on the B.I.G.-EU website

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	Model 6610-0000

BIBBs Tested

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	COV-B	DS-COV-B
	COV-Unsolicited-A	DS-COVU-A
COV-Unsolicited-B	DS-COVU-B	

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	ACK-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Information B	AE-INFO-B

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Connection Establishment-A	NM-CE-A

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	Event Enrollment
File	Multi-State Input	Multi-State Output
Multi-State Value	Notification Class	Schedule
Trend Log		

Data Link Layer Options

Media	Options
BACnet IP (Annex J)	

Networking Options

Networking Functionality	Media
Annex J BBMD	BACnet/IP

Character Set Support

ANSI X3.4
