



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 / ISO 16484-5 is the responsibility of the BACnet Interest Group Europe e. V. (B.I.G.-EU). BTL is a registered trademark of BACnet International (BI).

## BACnet Testing Laboratories Product Listing

*This product has been tested at the BACnet Testing Laboratory WSPLab and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the B.I.G.-EU website under "Product Catalogue".*

### Listing Information

Test Laboratory		Listing Status
WSPLab Dr.-Ing. Harald Bitter Kapuzinerweg 7 D-70374 Stuttgart		
Vendor		Listed Product
TAC, LLC 1 High St. North Andover MA USA		
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of December 2007	Revision 4 (ISO 16484-5:2007)	April 2008

Product Name	Model Number	Firmware Revision
Andover Continuum bCX1 Series	bCX1-CR	Bootloader 4.500046 / Firmware 4.500046

Product Name	Link to PICS
Andover Continuum bCX1 Series	see "Product Catalogue" on the B.I.G.-EU website

### Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	bCX1-CR

## BIBBs Tested

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
COV-B	DS-COV-B	

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	ACK-B	AE-ACK-B
	Information B	AE-INFO-B

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Connection Establishment-A	NM-CE-A

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Command	Device
Event Enrollment	File	Loop
Multi-State Input	Multi-State Output	Multi-State Value
Notification Class	Program	Schedule
Trend Log		

## Data Link Layer Options

Media	Options
BACnet IP (Annex J)	
MS/TP master	9600,19200,38400,76800

## Networking Options

Networking Functionality	Media
Annex J BBMD	BACnet/IP

## Character Set Support

ANSI X3.4
-----------