

WSPCert Certificate

No. BAC-0173-02

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5:2012. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed in the annex of this certificate.

The BACnet Smart Sensor (B-SS)

EE160, EE210

with the software version:

1.8

of

E+E Elektronik Ges.m.b.H.

Langwiesen 7, 4209 Engerwitzdorf, Austria

has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 12.0 and the Certification Rules of the BACnet Interest Group Europe, see **MBS Test Report No. VG 2014_9451**.

The certificate is valid
until 2017/04/01

Date of renewal
2016/03/31

2015/03/02

Date of initial certification



Dipl.-Ing. G. Weinmann
Head of Certification Body

Empowered by
 **BACnet**
INTEREST GROUP EUROPE

Annex to Certificate No. BAC-0173-02

The certification of the BACnet Implementations
EE160, EE210
of **E+E Elektronik Ges.m.b.H.**

refers to the BACnet Interoperability Building Blocks (BIBBs) listed below. BIBBs other than listed are not part of the certification.

BACnet Interoperability Building Blocks	
DS-RP-B	Data Sharing – Read Property – B
DS-RPM-B	Data Sharing – Read Property Multiple – B
DS-WP-B	Data Sharing – Write Property – B
DM-DDB-B	Device Management – Dynamic Device Binding – B
DM-DOB-B	Device Management – Dynamic Object Binding – B
DM-DCC-B	Device Management – Device Communication Control – B
DM-RD-B	Device Management – Reinitialize Device – B