

WSPCert Certificate

No. BAC-0199-01

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5:2012. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed in the annex of this certificate.

The BACnet Application Specific Controller (B-ASC)

IO 420

with the software version:

2.0

of

GEZE GmbH

Reinhold-Vöster-Str. 21-29, 71229 Leonberg, Germany

has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 12.0 and the Certification Rules of the BACnet Interest Group Europe, see **MBS Test Report No. VG 2016_11217**.

The certificate is valid
until 2017/04/01

2016/04/07

Date of initial certification



Dipl.-Ing. G. Weinmann
Head of Certification Body

Empowered by
 **BACnet**
INTEREST GROUP EUROPE

Annex to Certificate No. BAC-0199-01

The certification of the BACnet Implementation
IO 420
of **GEZE GmbH**

refers to the BACnet Interoperability Building Blocks (BIBBs) listed below. BIBBs other than listed are not part of the certification.

| BACnet Interoperability Building Blocks | |
|--|---|
| DS-RP-B | Data Sharing – Read Property – B |
| DS-RPM-B | Data Sharing – Read Property Multiple – B |
| DS-WP-B | Data Sharing – Write Property – B |
| DS-WPM-B | Data Sharing – Write Property Multiple – B |
| DS-COV-B | Data Sharing – COV – B |
| AE-N-I-B | Alarm and Event – Notification Internal – B |
| AE-ACK-B | Alarm and Event – Acknowledge Alarm – B |
| AE-ASUM-B | Alarm and Event – Alarm Summary – B |
| AE-ESUM-B | Alarm and Event Management – Event-Enrollment Summary – B |
| AE-INFO-B | Alarm and Event – Information – B |
| DM-DDB-A | Device Management – Dynamic Device Binding – A |
| DM-DDB-B | Device Management – Dynamic Device Binding – B |
| DM-DOB-B | Device Management – Dynamic Object Binding – B |
| DM-DCC-B | Device Management – Device Communication Control – B |
| DM-TS-B | Device Management – Time Synchronization – B |
| DM-UTC-B | Device Management – UTC Time Synchronization – B |
| DM-RD-B | Device Management – Reinitialize Device – B |
| DM-R-B | Device Management – Restart – B |
| DM-LM-B | Device Management – List Manipulation – B |