

E-DDC3.3 S

SE-Elektronic GmbH

February 13, 2015

Contents

1 Protocol Implementation Conformance Statement (PICS)	2
1.1 BACnet Standardized Device Profile (Annex L)	2
1.2 BACnet interoperability building blocks supported (Annex K)	3
1.2.1 Data Sharing	3
1.2.2 Alarm and Event Management	3
1.2.3 Scheduling	3
1.2.4 Trending	3
1.2.5 Device and Network Management	4
1.3 BACnet object types supported	5
1.3.1 AnalogInput	6
1.3.2 AnalogOutput	7
1.3.3 AnalogValue	8
1.3.4 BinaryInput	9
1.3.5 BinaryOutput	10
1.3.6 BinaryValue	11
1.3.7 Calendar	12
1.3.8 Command	13
1.3.9 Device	14
1.3.10 EventEnrollment	16
1.3.11 File	17
1.3.12 Group	18
1.3.13 Loop	19
1.3.14 MultiStateInput	20
1.3.15 MultiStateOutput	21
1.3.16 NotificationClass	22
1.3.17 Program	23
1.3.18 Schedule	24
1.3.19 Averaging	25
1.3.20 MultiStateValue	26
1.3.21 TrendLog	27
1.3.22 Accumulator	28
1.3.23 PulseConverter	29
1.3.24 EventLog	30
1.3.25 TrendLogMultiple	31
1.3.26 LoadControl	32
1.3.27 StructuredView	33
1.3.28 AccessDoor	34
1.3.29 BitstringValue	35
1.3.30 DateValue	36
1.3.31 IntegerValue	37
1.3.32 PositiveIntegerValue	38
1.3.33 TimeValue	39
1.4 Segmentation capability	40
1.5 Data Link Layer options	40
1.6 Device address binding	40
1.7 Networking options	40
1.8 Character sets supported	40

1 Protocol Implementation Conformance Statement (PICS)

ANNEX A - PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT (NORMATIVE)

Date	February 13, 2015
Vendor Name	SE-Elektronik GmbH
Product Name:	E-DDC3.3 S
Application Software Version:	— (Project dependent)
Firmware Revision:	03.06.05
Product Model Number:	G 02 90 70
BACnet Protocol Revision:	Version 1, Revision 12, (135-2010)
Product Description:	The E-DDC is a freely configurable DDC-controller with focus on HVAC. The DDC-controller uses Server and Client functionality for peer to peer communication with other BACnet-Servers and supports the BBMD functionality.

1.1 BACnet Standardized Device Profile (Annex L)

- BACnet Operator Workstation (B-OWS)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

1.2 BACnet interoperability building blocks supported (Annex K)

1.2.1 Data Sharing

Data Sharing	
BIBB	Description
DS-RP-A	ReadProperty-A
DS-RP-B	ReadProperty-B
DS-RPM-A	ReadPropertyMultiple-A
DS-RPM-B	ReadPropertyMultiple-B
DS-WP-A	WriteProperty-A
DS-WP-B	WriteProperty-B
DS-WPM-A	WritePropertyMultiple-A
DS-WPM-B	WritePropertyMultiple-B
DS-COV-A	ChangeofValue-A
DS-COV-B	ChangeofValue-B
DS-COVP-A	ChangeofValueProperty-A
DS-COVP-B	ChangeofValueProperty-B
DS-COVU-A	ChangeofValue-Unsolicited-A
DS-COVU-B	ChangeofValue-Unsolicited-B
DS-RR-B	Read Range-B

1.2.2 Alarm and Event Management

Alarm and Event Management	
BIBB	Description
AE-N-A	Notification-A
AE-N-I-B	Notification Internal-B
AE-N-E-B	Notification External-B
AE-ACK-B	ACK-B
AE-ASUM-B	Alarm Summary-B
AE-ESUM-B	Enrollment Summary-B
AE-INFO-B	Information-B
AE-EL-I-B	Event Log - Internal - B
AE-EL-E-B	Event Log - Extenal - B

1.2.3 Scheduling

Scheduling	
BIBB	Description
SCHED-I-B	Scheduling-Internal-B
SCHED-E-B	Scheduling-External-B

1.2.4 Trending

Trending	
BIBB	Description
T-VMT-I-B	Viewing and Modifying Internal-B
T-VMT-E-B	Viewing and Modifying External-B
T-ATR-B	Automated Trend Retrieval-B
T-VMMV-I-B	Viewing and Modifying Multiple Values Internal-B
T-VMMV-E-B	Viewing and Modifying Multiple Values External-B
T-AMVR-B	Automated Multiple Value Retrieval-B

1.2.5 Device and Network Management

Device and Network Management	
BIBB	Description
DM-DDB-A	Dynamic Device Binding-A
DM-DDB-B	Dynamic Device Binding-B
DM-DOB-A	Dynamic Object Binding-A
DM-DOB-B	Dynamic Object Binding-B
DM-DCC-B	DeviceCommunicationControl-B
DM-TS-A	TimeSynchronization-A
DM-TS-B	TimeSynchronization-B
DM-UTC-A	UTCTimeSynchronization-A
DM-UTC-B	UTCTimeSynchronization-B
DM-RD-B	ReinitializeDevice-B
DM-BR-B	Backup and Restore-B
DM-R-B	Restart-B
DM-LM-B	List Manipulation-B
DM-OCD-B	Object Creation and Deletion-B
NM-CE-A	Connection Establishment-A
NM-CE-B	Connection Establishment-B
NM-RC-B	Router Configuration-B
DM-ATS-A	Automatic Time Synchronization-A
DM-MTS-A	Manual Time Synchronization-A

1.3 BACnet object types supported

BACnet object types supported		
Object Type	Dynamically Creatable	Dynamically Deletable
AnalogInput (AI)	-	-
AnalogOutput (AO)	-	-
AnalogValue (AV)	-	-
BinaryInput (BI)	-	-
BinaryOutput (BO)	-	-
BinaryValue (BV)	-	-
Calendar (CAL)	X	X
Command (CMD)	X	X
Device (DEV)	-	-
EventEnrollment (EE)	X	X
File (FIL)	-	X
Group (GRP)	X	X
Loop (LOO)	-	-
MultiStateInput (MI)	-	-
MultiStateOutput (MO)	-	-
NotificationClass (NC)	X	X
Program (PRG)	-	-
Schedule (SCH)	X	X
Averaging (AVG)	-	-
MultiStateValue (MV)	-	-
TrendLog (TL)	X	X
Accumulator (ACU)	-	-
PulseConverter (PC)	-	-
EventLog (EVL)	X	X
TrendLogMultiple (TLM)	X	X
LoadControl (LDC)	-	-
StructuredView (SV)	X	X
AccessDoor (ACD)	-	-
BitstringValue (BIT)	-	-
DateValue (DA)	-	-
IntegerValue (INT)	-	-
PositiveIntegerValue (POS)	-	-
TimeValue (TI)	-	-

1.3.1 AnalogInput

Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Notification_Class	Unsigned	W	-
Cov_Increment	REAL	W	-
Deadband	REAL	W	-
Description	CharacterString	W	0 .. 255 Bytes
Device_Type	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
High_Limit	REAL	W	-
Limit_Enable	BIT STRING	W	-
Low_Limit	REAL	W	-
Max_Pres_Value	REAL	W	-
Min_Pres_Value	REAL	W	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	REAL	W	-
Reliability	ENUMERATED	W	-
Resolution	REAL	R	-
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Units	ENUMERATED	W	-
Update_Interval	Unsigned	R	-
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Reliability [516]	Unsigned	R	-
159-Dp_Kind [522]	ENUMERATED	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Min_Dp_Value [546]	INTEGER	R	-
159-Max_Dp_Value [547]	INTEGER	R	-
159-Min_Obj_Value [548]	REAL	R	-
159-Max_Obj_Value [549]	REAL	R	-
159-Attenuation_Dp [550]	Unsigned	W	-
159-Reliability_Range [556]	Unsigned	R	-
159-Offset [560]	REAL	W	-

1.3.2 AnalogOutput

Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Notification_Class	Unsigned	W	-
Cov_Increment	REAL	W	-
Deadband	REAL	W	-
Description	CharacterString	W	0 .. 255 Bytes
Device_Type	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
High_Limit	REAL	W	-
Limit_Enable	BIT STRING	W	-
Low_Limit	REAL	W	-
Max_Pres_Value	REAL	W	-
Min_Pres_Value	REAL	W	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	REAL	W	-
Priority_Array	BACnetPriorityArray	R	-
Reliability	ENUMERATED	W	-
Relinquish_Default	REAL	W	-
Resolution	REAL	R	-
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Units	ENUMERATED	W	-
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Overridden [515]	Unsigned	R	-
159-Dpref_Reliability [516]	Unsigned	R	-
159-Dp_Kind [522]	ENUMERATED	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Min_Dp_Value [546]	INTEGER	R	-
159-Max_Dp_Value [547]	INTEGER	R	-
159-Min_Obj_Value [548]	REAL	R	-
159-Max_Obj_Value [549]	REAL	R	-
159-Reliability_Range [556]	Unsigned	R	-
159-Offset [560]	REAL	W	-

1.3.3 AnalogValue

Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Notification_Class	Unsigned	W	-
Cov_Increment	REAL	W	-
Deadband	REAL	W	-
Description	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
High_Limit	REAL	W	-
Limit_Enable	BIT STRING	W	-
Low_Limit	REAL	W	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	REAL	W	-
Priority_Array	BACnetPriorityArray	R	not available if Profile_Name 159-1
Reliability	ENUMERATED	W	-
Relinquish_Default	REAL	W	not available if Profile_Name 159-1
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Units	ENUMERATED	W	-
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Reliability [516]	Unsigned	R	-
159-Dp_Kind [522]	ENUMERATED	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Min_Dp_Value [546]	INTEGER	R	-
159-Max_Dp_Value [547]	INTEGER	R	-
159-Min_Obj_Value [548]	REAL	R	-
159-Max_Obj_Value [549]	REAL	R	-
159-Reliability_Range [556]	Unsigned	R	-

1.3.4 BinaryInput

Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Active_Text	CharacterString	W	0 .. 255 Bytes
Alarm_Value	ENUMERATED	W	-
Change_Of_State_Count	Unsigned	W	only 0 writeable
Change_Of_State_Time	BACnetDateTime	R	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Device_Type	CharacterString	W	0 .. 255 Bytes
Elapsed_Active_Time	Unsigned	W	only 0 writeable
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Inactive_Text	CharacterString	W	0 .. 255 Bytes
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Polarity	ENUMERATED	W	-
Present_Value	ENUMERATED	W	-
Reliability	ENUMERATED	W	-
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Time_Of_Active_Time_Reset	BACnetDateTime	R	-
Time_Of_State_Count_Reset	BACnetDateTime	R	-
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Reliability [516]	Unsigned	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Reliability_Range [556]	Unsigned	R	-

1.3.5 BinaryOutput

Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Active_Text	CharacterString	W	0 .. 255 Bytes
Change_Of_State_Count	Unsigned	W	only 0 writeable
Change_Of_State_Time	BACnetDateTime	R	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Device_Type	CharacterString	W	0 .. 255 Bytes
Elapsed_Active_Time	Unsigned	W	only 0 writeable
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Feedback_Value	ENUMERATED	R	-
Inactive_Text	CharacterString	W	0 .. 255 Bytes
Minimum_Off_Time	Unsigned	W	-
Minimum_On_Time	Unsigned	W	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Polarity	ENUMERATED	W	-
Present_Value	ENUMERATED	W	-
Priority_Array	BACnetPriorityArray	R	-
Reliability	ENUMERATED	W	-
Relinquish_Default	ENUMERATED	W	-
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Time_Of_Active_Time_Reset	BACnetDateTime	R	-
Time_Of_State_Count_Reset	BACnetDateTime	R	-
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Overridden [515]	Unsigned	R	-
159-Dpref_Reliability [516]	Unsigned	R	-
159-Dpref_Feedback [517]	Unsigned	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Reliability_Range [556]	Unsigned	R	-

1.3.6 BinaryValue

Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Active_Text	CharacterString	W	0 .. 255 Bytes
Alarm_Value	ENUMERATED	W	-
Change_Of_State_Count	Unsigned	W	only 0 writeable
Change_Of_State_Time	BACnetDateTime	R	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Elapsed_Active_Time	Unsigned	W	only 0 writeable
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Inactive_Text	CharacterString	W	0 .. 255 Bytes
Minimum_Off_Time	Unsigned	W	not available if Profile_Name 159-1
Minimum_On_Time	Unsigned	W	not available if Profile_Name 159-1
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	ENUMERATED	W	-
Priority_Array	BACnetPriorityArray	R	not available if Profile_Name 159-1
Reliability	ENUMERATED	W	-
Relinquish_Default	ENUMERATED	W	not available if Profile_Name 159-1
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Time_Of_Active_Time_Reset	BACnetDateTime	R	-
Time_Of_State_Count_Reset	BACnetDateTime	R	-
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Reliability [516]	Unsigned	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Reliability_Range [556]	Unsigned	R	-

1.3.7 Calendar

Calendar			
Property	Datatype	W	Restrictions
Date_List	ListOfBACnetCalendarEntry	W	0 .. 32
Description	CharacterString	W	0 .. 255 Bytes
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Present_Value	BOOLEAN	R	-
Profile_Name	CharacterString	R	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.8 Command

Command			
Property	Datatype	W	Restrictions
Action	ArrayOfBACnetActionList	W	12x 11 Actions
Action_Text	ArrayOfCharacterString	W	12x 0 .. 255 Bytes
All_Writes_Successful	BOOLEAN	R	-
Description	CharacterString	W	0 .. 255 Bytes
In_Process	BOOLEAN	R	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Present_Value	Unsigned	W	-
Profile_Name	CharacterString	R	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.9 Device

Device Property	Datatype	W	Restrictions
Apdu_Segment_Timeout	Unsigned	W	-
Apdu_Timeout	Unsigned	W	-
Application_Software_Version	CharacterString	R	0 .. 255 Bytes
Daylight_Savings_Status	BOOLEAN	R	-
Description	CharacterString	W	0 .. 255 Bytes
Device_Address_Binding	ListOfBACnetAddressBinding	R	-
Firmware_Revision	CharacterString	R	0 .. 255 Bytes
Local_Date	Date	R	-
Local_Time	Time	R	-
Location	CharacterString	W	0 .. 255 Bytes
Max_Apdu_Length_Accepted	Unsigned	R	-
Max_Info_Frames	Unsigned	W	1 .. 10
Max_Master	Unsigned	W	1 .. 127
Model_Name	CharacterString	R	0 .. 255 Bytes
Number_Of_APDU_Retries	Unsigned	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_List	ArrayOfBACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Protocol_Object_Types_Supported	BIT STRING	R	-
Protocol_Services_Supported	BIT STRING	R	-
Protocol_Version	Unsigned	R	-
Segmentation_Supported	ENUMERATED	R	-
System_Status	ENUMERATED	R	-
Time_Synchronization_Recipients	ListOfBACnetRecipient	W	-
Utc_Offset	INTEGER	R	-780 .. +780
Vendor_Identifier	Unsigned	R	-
Vendor_Name	CharacterString	R	0 .. 255 Bytes
Protocol_Revision	Unsigned	R	-
Active_Cov_Subscriptions	ListOfBACnetCovSubscription	W	-
Backup_Failure_Timeout	Unsigned	W	1 .. 65535
Configuration_Files	ArrayOfBACnetObjectIdentifier	R	-
Database_Revision	Unsigned	R	-
Last_Restore_Time	BACnetTimeStamp	R	-
Max_Segments_Accepted	Unsigned	R	-
Profile_Name	CharacterString	R	-
Align_Intervals	BOOLEAN	W	resolution 1s
Interval_Offset	Unsigned	W	resolution 1s
Last_Restart_Reason	ENUMERATED	R	-
Restart_Notification_Recipients	ListOfBACnetRecipient	W	0 .. 32
Time_Of_Device_Restart	BACnetTimeStamp	R	-
Time_Synchronization_Interval	Unsigned	W	-
Utc_Time_Synchronization_Recipients	ListOfBACnetRecipient	W	0 .. 32
Structured_Object_List	ArrayOfBACnetObjectIdentifier	W	-
Backup_And_Restore_State	ENUMERATED	R	-
Backup_Preparation_Time	Unsigned	R	-
Restore_Completion_Time	Unsigned	R	-
Restore_Preparation_Time	Unsigned	R	-
159-Latitude [520]	REAL	W	-
159-Longitude [521]	REAL	W	-
159-Vlt_Support [523]	BOOLEAN	R	-
159-Object_List_Oos [537]	ArrayOfBACnetObjectIdentifier	R	-
159-Serial_Number [555]	CharacterString	R	0 .. 255 Bytes
159-Languages [557]	ArrayOfCharacterString	R	0 .. 255 Bytes

... Device continued			
Property	Datatype	W	Restrictions
159-Elevation [559]	REAL	W	-
159-Ack_All [561]	BOOLEAN	W	-

1.3.10 EventEnrollment

EventEnrollment			
Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Event_Type	ENUMERATED	R	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Property_Reference	BACnetDeviceObjectPropertyReference	W	-
Object_Type	ENUMERATED	R	-
Event_Parameters	BACnetEventParameter	W	-
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Object_Flags [544]	BIT STRING	R	-

1.3.11 File

File			
Property	Datatype	W	Restrictions
Archive	BOOLEAN	W	-
Description	CharacterString	W	0 .. 255 Bytes
File_Access_Method	ENUMERATED	R	-
File_Size	Unsigned	W	0 writeable only during restore
File_Type	CharacterString	R	0 .. 255 Bytes
Modification_Date	BACnetDateTime	R	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	R	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Read_Only	BOOLEAN	R	-
Profile_Name	CharacterString	R	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.12 Group

Group			
Property	Datatype	W	Restrictions
Description	CharacterString	W	0 .. 255 Bytes
List_Of_Group_Members	ListOfBACnetReadAccessSpecification	W	64 Objects with 4 Properties
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Present_Value	ListOfBACnetReadAccessResult	R	-
Profile_Name	CharacterString	W	-
159-Id [536]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.13 Loop

Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Action	ENUMERATED	W	-
Bias	REAL	W	-
Notification_Class	Unsigned	W	-
Controlled_Variable_Reference	BACnetObjectPropertyReference	W	-
Controlled_Variable_Units	ENUMERATED	R	-
Controlled_Variable_Value	REAL	R	-
Cov_Increment	REAL	W	-
Deadband	REAL	W	-
Derivative_Constant	REAL	W	-
Derivative_Constant_Units	ENUMERATED	R	-
Description	CharacterString	W	0 .. 255 Bytes
Error_Limit	REAL	W	-
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Integral_Constant	REAL	W	-
Integral_Constant_Units	ENUMERATED	R	-
Manipulated_Variable_Reference	BACnetObjectPropertyReference	W	-
Maximum_Output	REAL	W	-
Minimum_Output	REAL	W	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Output_Units	ENUMERATED	R	-
Present_Value	REAL	W	-
Priority_For_Writing	Unsigned	W	-
Proportional_Constant	REAL	W	-
Proportional_Constant_Units	ENUMERATED	W	-
Reliability	ENUMERATED	R	-
Setpoint	REAL	W	-
Setpoint_Reference	BACnetSetpointReference	W	-
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Update_Interval	Unsigned	W	100 .. 1000 ms
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	W	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Comment [535]	CharacterString	R	0 .. 255 Bytes
159-Covu_Nc [538]	Unsigned	W	-
159-Integral_Stop [542]	BOOLEAN	W	-
159-Neutralize [543]	BOOLEAN	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Derivative_Filter_Constant [551]	REAL	W	-
159-Integral_High_Limit [552]	REAL	W	-
159-Integral_Low_Limit [553]	REAL	W	-
159-Deviation_Deadband [554]	REAL	W	-

1.3.14 MultiStateInput

MultiStateInput			
Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Alarm_Values	ListOfUnsigned	W	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Device_Type	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Fault_Values	ListOfUnsigned	W	-
Notify_Type	ENUMERATED	W	-
Number_Of_States	Unsigned	R	up to 128
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	Unsigned	W	-
Reliability	ENUMERATED	W	-
State_Text	ArrayOfCharacterString	W	up to 128x 0 .. 255 Bytes
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Reliability [516]	Unsigned	R	-
159-Dp_Kind [522]	ENUMERATED	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.15 MultiStateOutput

MultiStateOutput Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Device_Type	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Feedback_Value	Unsigned	R	-
Notify_Type	ENUMERATED	W	-
Number_Of_States	Unsigned	R	up to 128
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	Unsigned	W	-
Priority_Array	BACnetPriorityArray	R	-
Reliability	ENUMERATED	W	-
Relinquish_Default	Unsigned	W	-
State_Text	ArrayOfCharacterString	W	up to 128x 0 .. 255 Bytes
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Overridden [515]	Unsigned	R	-
159-Dpref_Reliability [516]	Unsigned	R	-
159-Dpref_Feedback [517]	Unsigned	R	-
159-Dp_Kind [522]	ENUMERATED	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.16 NotificationClass

NotificationClass			
Property	Datatype	W	Restrictions
Ack_Required	BIT STRING	W	-
Notification_Class	Unsigned	R	-
Description	CharacterString	W	0 .. 255 Bytes
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Priority	ArrayOfUnsigned	W	-
Recipient_List	ListOfBACnetDestination	W	-
Profile_Name	CharacterString	R	-
159-Covu_Period [539]	Unsigned	W	-
159-Covu_Referenced_Objects [540]	ArrayOfBACnetObjectIdentifier	R	-
159-Nc_Referenced_Objects [541]	ArrayOfBACnetObjectIdentifier	R	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.17 Program

Property	Datatype	W	Restrictions
Program			
Description	CharacterString	W	0 .. 255 Bytes
Description_Of_Halt	CharacterString	R	0 .. 255 Bytes
Instance_Of	CharacterString	W	0 .. 255 Bytes
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Program_Change	ENUMERATED	W	-
Program_Location	CharacterString	W	0 .. 255 Bytes
Program_State	ENUMERATED	R	-
Reason_For_Halt	ENUMERATED	R	-
Reliability	ENUMERATED	R	-
Status_Flags	BIT STRING	R	-
Profile_Name	CharacterString	W	-
159-Comment [535]	CharacterString	R	0 .. 255 Bytes
159-Id [536]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Internal_State [558]	CharacterString	R	0 .. 255 Bytes

1.3.18 Schedule

Schedule			
Property	Datatype	W	Restrictions
Description	CharacterString	W	0 .. 255 Bytes
Effective_Period	BACnetDateRange	W	-
Exception_Schedule	ArrayOfBACnetSpecialEvent	W	0 .. 10 x 1 .. 32 entries
List_Of_Object_Property_References	ListOfBACnetDeviceObjectPropertyReference	W	1 .. 16
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	any primitive	W	-
Priority_For_Writing	Unsigned	W	-
Reliability	ENUMERATED	R	-
Status_Flags	BIT STRING	R	-
Weekly_Schedule	ArrayOfBACnetDailySchedule	W	0 .. 32 per day
Profile_Name	CharacterString	R	-
Schedule_Default	any primitive	W	-
159-Next_Exec_Time [518]	Time	R	-
159-Next_Exec_Val [519]	any primitive	R	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.19 Averaging

Averaging			
Property	Datatype	W	Restrictions
Description	CharacterString	W	0 .. 255 Bytes
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Property_Reference	BACnetDeviceObjectPropertyReference	W	local device only
Object_Type	ENUMERATED	R	-
Attempted_Samples	Unsigned	W	only 0 writeable
Average_Value	REAL	R	-
Maximum_Value	REAL	R	-
Minimum_Value	REAL	R	-
Valid_Samples	Unsigned	R	-
Window_Interval	Unsigned	W	-
Window_Samples	Unsigned	W	1 .. 580
Maximum_Value_Timestamp	BACnetDateTime	R	-
Minimum_Value_Timestamp	BACnetDateTime	R	-
Profile_Name	CharacterString	W	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.20 MultiStateValue

MultiStateValue			
Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Alarm_Values	ListOfUnsigned	W	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Fault_Values	ListOfUnsigned	W	-
Notify_Type	ENUMERATED	W	-
Number_Of_States	Unsigned	R	up to 128
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	Unsigned	W	-
Priority_Array	BACnetPriorityArray	R	not available if Profile_Name 159-1
Reliability	ENUMERATED	W	-
Relinquish_Default	Unsigned	W	not available if Profile_Name 159-1
State_Text	ArrayOfCharacterString	W	up to 128x 0 .. 255 Bytes
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Reliability [516]	Unsigned	R	-
159-Dp_Kind [522]	ENUMERATED	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.21 TrendLog

TrendLog			
Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Reliability	ENUMERATED	R	-
Status_Flags	BIT STRING	R	-
Buffer_Size	Unsigned	W	power of 2; 64 .. 262144
Client_Cov_Increment	BACnetClientCOV	W	-
Cov_Resubscription_Interval	Unsigned	W	-
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Log_Buffer	ListOfBACnetLogRecord	R	-
Log_Device_Object_Property	BACnetDeviceObjectPropertyReference	W	-
Enable	BOOLEAN	W	-
Log_Interval	Unsigned	W	0; 100ms .. 48h
Notification_Threshold	Unsigned	W	-
Records_Since_Notification	Unsigned	R	-
Record_Count	Unsigned	W	only 0 writeable
Start_Time	BACnetDateTime	W	-
Stop_Time	BACnetDateTime	W	-
Stop_When_Full	BOOLEAN	W	-
Total_Record_Count	Unsigned	R	-
Profile_Name	CharacterString	R	-
Last_Notify_Record	Unsigned	R	-
Align_Intervals	BOOLEAN	W	resolution 1s
Interval_Offset	Unsigned	W	resolution 1s
Logging_Type	ENUMERATED	W	-
Trigger	BOOLEAN	W	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Last_Read_Sequence [531]	ArrayOfBACnetSeLastReadSequence	W	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.22 Accumulator

Accumulator			
Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Device_Type	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
High_Limit	Unsigned	W	-
Limit_Enable	BIT STRING	W	-
Low_Limit	Unsigned	W	-
Max_Pres_Value	Unsigned	R	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	Unsigned	W	-
Reliability	ENUMERATED	W	-
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Units	ENUMERATED	W	-
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Limit_Monitoring_Interval	Unsigned	W	-
Logging_Object	BACnetObjectIdentifier	W	-
Logging_Record	BACnetAccumulatorRecord	R	-
Prescale	BACnetPrescale	W	-
Pulse_Rate	Unsigned	W	-
Scale	BACnetScale	W	-
Value_Before_Change	Unsigned	R	-
Value_Set	Unsigned	W	-
Value_Change_Time	BACnetDateTime	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Reliability [516]	Unsigned	R	-
159-Object_Flags [544]	BIT STRING	R	-
159-Reliability_Range [556]	Unsigned	R	-

1.3.23 PulseConverter

PulseConverter		W	Restrictions
Property	Datatype		
Acked_Transitions	BIT STRING	R	-
Notification_Class	Unsigned	W	-
Cov_Increment	REAL	W	-
Deadband	REAL	W	-
Description	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
High_Limit	REAL	W	-
Limit_Enable	BIT STRING	W	-
Low_Limit	REAL	W	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	REAL	W	-
Reliability	ENUMERATED	W	-
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Units	ENUMERATED	W	-
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Adjust_Value	REAL	W	-
Count	Unsigned	R	-
Count_Before_Change	Unsigned	R	-
Count_Change_Time	BACnetDateTime	R	-
Cov_Period	Unsigned	W	-
Input_Reference	BACnetObjectPropertyReference	W	Accumulator Present_Value
Scale_Factor	REAL	W	-
Update_Time	BACnetDateTime	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Reliability_Range [556]	Unsigned	R	-

1.3.24 EventLog

EventLog Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Reliability	ENUMERATED	R	-
Status_Flags	BIT STRING	R	-
Buffer_Size	Unsigned	W	power of 2; 64 .. 262144
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Log_Buffer	ListOfBACnetEventLogRecord	R	-
Enable	BOOLEAN	W	-
Notification_Threshold	Unsigned	W	-
Records_Since_Notification	Unsigned	R	-
Record_Count	Unsigned	W	only 0 writeable
Start_Time	BACnetDateTime	W	-
Stop_Time	BACnetDateTime	W	-
Stop_When_Full	BOOLEAN	W	-
Total_Record_Count	Unsigned	R	-
Profile_Name	CharacterString	R	-
Last_Notify_Record	Unsigned	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Last_Read_Sequence [531]	ArrayOfBACnetSeLastReadSequence	W	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.25 TrendLogMultiple

TrendLogMultiple			
Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Reliability	ENUMERATED	R	-
Status_Flags	BIT STRING	R	-
Buffer_Size	Unsigned	W	power of 2; 64 .. 262144
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Log_Buffer	ListOfBACnetLogMultiRecord	R	-
Log_Device_Object_Property	ArrayOfBACnetDeviceObjectPropertyReference	W	-
Enable	BOOLEAN	W	-
Log_Interval	Unsigned	W	0; 100ms .. 48h
Notification_Threshold	Unsigned	W	-
Records_Since_Notification	Unsigned	R	-
Record_Count	Unsigned	W	only 0 writeable
Start_Time	BACnetDateTime	W	-
Stop_Time	BACnetDateTime	W	-
Stop_When_Full	BOOLEAN	W	-
Total_Record_Count	Unsigned	R	-
Profile_Name	CharacterString	R	-
Last_Notify_Record	Unsigned	R	-
Align_Intervals	BOOLEAN	W	resolution 1s
Interval_Offset	Unsigned	W	resolution 1s
Logging_Type	ENUMERATED	W	-
Trigger	BOOLEAN	W	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Last_Read_Sequence [531]	ArrayOfBACnetSeLastReadSequence	W	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.26 LoadControl

LoadControl			
Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Present_Value	ENUMERATED	R	-
Reliability	ENUMERATED	R	-
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Enable	BOOLEAN	W	-
Start_Time	BACnetDateTime	W	-
Profile_Name	CharacterString	R	-
Actual_Shed_Level	BACnetShedLevel	R	-
Duty_Window	Unsigned	W	-
Expected_Shed_Level	BACnetShedLevel	R	-
Full_Duty_Baseline	REAL	W	-
Requested_Shed_Level	BACnetShedLevel	W	-
Shed_Duration	Unsigned	W	-
Shed_Level_Descriptions	ArrayOfCharacterString	W	0 .. 255 Bytes
Shed_Levels	ArrayOfUnsigned	W	-
State_Description	CharacterString	R	0 .. 255 Bytes
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.27 StructuredView

StructuredView			
Property	Datatype	W	Restrictions
Description	CharacterString	W	0 .. 255 Bytes
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Profile_Name	CharacterString	W	-
Node_Subtype	CharacterString	W	0 .. 255 Bytes
Node_Type	ENUMERATED	W	-
Subordinate_Annotations	ArrayOfCharacterString	W	up to 128x 0 .. 255 Bytes
Subordinate_List	ArrayOfBACnetDeviceObjectReference	W	up to 128
159-Subordinate_Instance [524]	BOOLEAN	W	-
159-Object_Flags [544]	BIT STRING	R	-

1.3.28 AccessDoor

AccessDoor			
Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Alarm_Values	ListOfENUMERATED	W	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Fault_Values	ListOfENUMERATED	W	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	ENUMERATED	W	-
Priority_Array	BACnetPriorityArray	R	not available if Profile_Name 159-1
Reliability	ENUMERATED	W	-
Relinquish_Default	ENUMERATED	W	not available if Profile_Name 159-1
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Maintenance_Required	ENUMERATED	R	-
Profile_Name	CharacterString	R	-
Door_Alarm_State	ENUMERATED	W	-
Door_Extended_Pulse_Time	Unsigned	W	-
Door_Members	ArrayOfBACnetDeviceObjectReference	R	-
Door_Open_Too_Long_Time	Unsigned	W	-
Door_Pulse_Time	Unsigned	W	-
Door_Status	ENUMERATED	W	-
Door_Unlock_Delay_Time	Unsigned	W	-
Lock_Status	ENUMERATED	W	-
Masked_Alarm_Values	ListOfENUMERATED	W	-
Secured_Status	ENUMERATED	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Reliability_Range [556]	Unsigned	R	-

1.3.29 BitstringValue

BitstringValue Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Alarm_Values	ArrayOfBIT STRING	W	-
Notification_Class	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	BIT STRING	W	-
Priority_Array	BACnetPriorityArray	R	not available if Profile_Name 159-1
Reliability	ENUMERATED	W	-
Relinquish_Default	BIT STRING	W	not available if Profile_Name 159-1
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Bit_Mask	BIT STRING	W	-
Bit_Text	ArrayOfCharacterString	W	0 .. 255 Bytes
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Reliability [516]	Unsigned	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Reliability_Range [556]	Unsigned	R	-

1.3.30 DateValue

DateValue			
Property	Datatype	W	Restrictions
Description	CharacterString	W	0 .. 255 Bytes
Event_State	ENUMERATED	R	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	Date	W	-
Priority_Array	BACnetPriorityArray	R	not available if Profile_Name 159-1
Reliability	ENUMERATED	W	-
Relinquish_Default	Date	W	not available if Profile_Name 159-1
Status_Flags	BIT STRING	R	-
Profile_Name	CharacterString	R	-
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Reliability [516]	Unsigned	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Reliability_Range [556]	Unsigned	R	-

1.3.31 IntegerValue

IntegerValue Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Notification_Class	Unsigned	W	-
Cov_Increment	Unsigned	W	-
Deadband	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
High_Limit	INTEGER	W	-
Limit_Enable	BIT STRING	W	-
Low_Limit	INTEGER	W	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	INTEGER	W	-
Priority_Array	BACnetPriorityArray	R	not available if Profile_Name 159-1
Reliability	ENUMERATED	W	-
Relinquish_Default	INTEGER	W	not available if Profile_Name 159-1
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Units	ENUMERATED	W	-
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Reliability [516]	Unsigned	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Reliability_Range [556]	Unsigned	R	-

1.3.32 PositiveIntegerValue

Property	Datatype	W	Restrictions
Acked_Transitions	BIT STRING	R	-
Notification_Class	Unsigned	W	-
Cov_Increment	Unsigned	W	-
Deadband	Unsigned	W	-
Description	CharacterString	W	0 .. 255 Bytes
Event_Enable	BIT STRING	W	-
Event_State	ENUMERATED	R	-
High_Limit	Unsigned	W	-
Limit_Enable	BIT STRING	W	-
Low_Limit	Unsigned	W	-
Notify_Type	ENUMERATED	W	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	Unsigned	W	-
Priority_Array	BACnetPriorityArray	R	not available if Profile_Name 159-1
Reliability	ENUMERATED	W	-
Relinquish_Default	Unsigned	W	not available if Profile_Name 159-1
Status_Flags	BIT STRING	R	-
Time_Delay	Unsigned	W	0 .. 6553 s
Units	ENUMERATED	W	-
Event_Time_Stamps	ArrayOfBACnetTimeStamp	R	-
Profile_Name	CharacterString	R	-
Event_Message_Texts	ArrayOfCharacterString	R	3x 0 .. 255 Bytes
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Reliability [516]	Unsigned	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Reliability_Range [556]	Unsigned	R	-

1.3.33 TimeValue

TimeValue			
Property	Datatype	W	Restrictions
Description	CharacterString	W	0 .. 255 Bytes
Event_State	ENUMERATED	R	-
Object_Identifier	BACnetObjectIdentifier	R	-
Object_Name	CharacterString	W	1 .. 255 Bytes
Object_Type	ENUMERATED	R	-
Out_Of_Service	BOOLEAN	W	-
Present_Value	Time	W	-
Priority_Array	BACnetPriorityArray	R	not available if Profile_Name 159-1
Reliability	ENUMERATED	W	-
Relinquish_Default	Time	W	not available if Profile_Name 159-1
Status_Flags	BIT STRING	R	-
Profile_Name	CharacterString	R	-
159-Dpref_Value [514]	Unsigned	W	DP Value
159-Dpref_Reliability [516]	Unsigned	R	-
159-Covu_Nc [538]	Unsigned	W	-
159-Object_Flags [544]	BIT STRING	R	-
159-Reliability_Range [556]	Unsigned	R	-

1.4 Segmentation capability

Segmented requests supported Windows Size:	4
Segmented responses supported Windows Size:	16

1.5 Data Link Layer options

The simultaneously supported Data Link Layers of a product are listed with the product model number.

Data Link Layer options

BACnet IP, (Annex J)	Ethernet 10/100 MB/s, USB 10 MB/s
BACnet IP, (Annex J), Foreign Device	-
ISO 8802-3, Ethernet (Clause 7)	-
ANSI/ATA 878.1,2.6 Mb. ARCNET (Clause 8)	-
ANSI/ATA 878.1,RS-485 ARCNET (Clause 8)	-
MS/TP Master (clase 9), baud rates:	9600, 19200, 38400, 57600, 76800, 115200
MS/TP Slave (clase 9), baud rates:	-
Point-To-Point, EIA 232 (Clause 10), baud rates:	9600, 19200, 38400, 57600, 76800, 115200
Point-To-Point, modem (Clause 10), baud rates:	9600, 19200, 38400, 57600, 76800, 115200
LonTalk, (Clause 11), medium: ... TF/FT-10	-

1.6 Device address binding

Is static device binding supported? Yes

1.7 Networking options

Networking options

Router, Clause 6 - List all routing configurations	IP-MS/TP, PTP-MS/TP, IP-PTP
Annex H, BACnet Tunneling Router over IP	-
BACnet/IP Broadcast Management Device (BBMD)	✓
- Number of BDT entries	32
- Number of FDT entries	8
Does the BBMD support registrations by Foreign Devices?	✓

1.8 Character sets supported

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

Character sets supported

ANSI X3.4	✓
ISO 10646 (UCS-2)	✓
IBM™/Microsoft™ DBCS	-
ISO 10646 (UCS-4)	✓
ISO 8859-1	✓
JIS C 6226	-
UTF-8	✓

SE-Elektronik GmbH

Eythstraße 16
73037 Göppingen

Tel. +49(0) 7161 - 95 84 - 0
Fax. +49(0) 7161 - 95 84 - 30

info@se-elektronik.de
www.se-elektronik.de

© Copyright 2015
All rights reserved